

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 13-Apr-2004	4. REQUISITION/PURCHASE REQ. NO.	1 3
6. ISSUED BY US ARMY ENGINEER DISTRICT SAVANNAH 100 W OGLETHORPE AVENUE SAVANNAH GA 31401-3640		CODE W912HN	7. ADMINISTERED BY (If other than item 6) See Item 6	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W912HN-04-R-0013
			X	9B. DATED (SEE ITEM 11) 10-Feb-2004
				10A. MOD. OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS	
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) PROJECT: D-AREA BARRACKS, PHASE IV, FORT BRAGG, NORTH CAROLINA POC: Sandy Meyers, (912) 652-5324 email: sandra.b.meyers@sas02.usace.army.mil See Page 2 for continuation				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	14-Apr-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

The following items are applicable to this modification:

Solicitation No. W912HN-04-R-0013, D-Area Barracks, Phase, IV, Fort Bragg, North Carolina

ONLY THE CONTRACTORS DETERMINED TO BE IN THE COMPETITIVE RANGE SHALL RESPOND TO THIS SOLICITATION.

This amendment is official notification that (1) your response to this amendment is considered discussions, and that upon your response, discussions will have been concluded; and (2) you are now afforded an opportunity to submit Final Proposal Revisions for this project. **REVISED PROPOSALS ARE DUE BY CLOSE OF BUSINESS 26 APRIL 2004.**

A. CONTRACT CHANGES:

Section 00010, BID SCHEDULE, has been revised. Replace with the attached Section 00010.

B. TECHNICAL SPECIFICATION CHANGES: See paragraph D of this amendment.

C. CONTRACT DRAWINGS: There are no revisions issued with this amendment.

D. REVISIONS TO SCOPE OF WORK:

General	Spec or Plate	Paragraph/Detail	Description
Landscaping	L3 (11&199)	Irrigation Plan	Delete Irrigation in courtyard. Keep all irrigation for areas adjacent to barracks buildings. Remove irrigation in the space between sidewalks and Merrill Street (Sheet 199), common area between D2822 and D2723, and common area behind Bldg D2420. Irrigation system supporting trees and other ground cover will remain in place
Civil	C5.1 (11&172)	Keynote 1	Change cast iron downspout boots from 80mm cast iron to 18" cast iron downspout boots.
Storm Drainage	02630A	2.1.1	Change storm drainage RCP to HEP corrugated pipe and fittings.
Tile	A63 (86 &246)	Detail: G Bath	Delete tile wainscot in bathroom and provide solid surfacing tub surround.
Countertops	12320A	2.2.2	Change solid surface counter tops and top edging to post formed plastic laminate tops
Vanity	A65 (88&248)	Detail 5	Change plastic laminate and solid surfacing sink to solid surfacing counter top and backsplash with integral sink.
	12320A	2.1	Change cabinet design with inlay and wood door border shown to flush door panel design with plastic laminate facing.
	12320A	2.1	Allow standard white melamine for interior of cabinet lining.
SCB-Tile	A61 (sht 365)	Finish Schedule	Where Finish Schedule shows POR1, change to VCT1. May use vinyl base.
SCB-Carpet	A61 (sht 365)	Finish Schedule	Where Finish Schedule shows CPT, change to VCT1. May use vinyl base.
Finish Carpentry	06200A	2.1.10	Change wood shoe mold, wood base, and related wood blocking to vinyl base.
Ceramic/ Porcelain	09310		Change ceramic wall tile around bathtub and change to solid surface shower wall panels in tub.

Tile			
Cast Stone Band	A21 (335) A20 (334)	Note 6	Change: Cast Stone to EIFS Band to match the cast stone color.
	A34 (67&225)	Detail 4 and Detail 1	Change: Note 9 to EIFS Band to match the cast stone color.
	A23 (60&218)	Detail 2	TYP BAND: Change to EIFS. (Others in detail, ie TYP SILL and SILL @ WALL remain cast stone)
	A25 (336)	TYP BAND	TYP BAND: Change to EIFS. (Others in detail to remain cast stone)
P/P Concrete Floor/Roof	03410A	S2.1 Dtl: 4,7,8 S3.1 Dtl: 1,2,3,4,5,6,7,8, 10,11,12 S3.2 Dtl: 4,5,6 S4.1 Dtl: 1,3,4,5	Change roof/floor Connection Details: Hollow Core slab manufacturer will redesign connections to meet minimum requirements for progressive collapse. (Manufacturer must meet UFC 4-010-01 minimum standard for Anti-terrorism.)
Plumbing, General Purp	15400A	Table 1	Change to allow use of PVC pipe, fittings, and accessories for drainage, waste and vent plumbing systems. PVC Sch 40 pipe to be used (no "PVC foam core pipe marked 'Not for Pressure'" to be used).
Contractor Quality Control	01451A	3.4.1	Delete requirement for Safety and Health Manager.
	01451A	3.4.3	Delete requirement for Submittal Clerk
	01451A	3.4.3	Delete requirement for Civil CQC
Special Inspection for Seismic Systems	01452A	1.3	Delete Paragraph 1.3